

CATAPULT

The Source term and Siting CATAPULT database

Fabrizio Gabrielli, Mauricio E. Cazado, Anastasia Stakhanova (KIT), Daniela Diaconu, Mirela Nitoi, Marin Constantin, Cristian Dulama, Minodora Apostol (RATEN), Anca Tacu (NRG Pallas), Päivi Roivainen, Tomi Routamo, Tuomas Peltonen, Mikko Voutilainen, Ellen Hiittenkivi (STUK)

The Database

- Providing the necessary data for dose impact and the environmental transport studies
- **Three generic modular reactors**
 - Water-cooled SMR (submerged containment, 60 MWe)
 - Lead-cooled ALFRED-like (125 MWe)
 - Gas-cooled HTR-like (200 Mwth)
- Characteristics of **four selected sites**

Database of the Source Terms

- **No extensive integral evaluations** of ST planned in CATAPULT → focus on the project on EIA and EP&R modelling and Social Sciences and Humanities Activities
- The **database based on first order estimates** (nominal and accident conditions)
 - Evaluation of fuel inventories
 - Available analyses by means integral codes
 - Application of release fractions to the initial inventory (open literature, reports)
- The database is a **living** source of information through the project

Water-cooled advanced modular reactor

Source Term

- Fuel inventories at different burn-up (20, 30, 40, 50, and 60 MWd/kgU) computed by CASMO (developed by Studsvik)
- **Nominal conditions** (atmospheric release)
- **Severe accidents** (atmospheric release)
 - Derived by large uncertainty analysis on PWR KONVOI (MBLOCA) - 5 STs
 - Directly evaluated for a generic SMR (LOCA+SBO) by means of the ASTEC code (developed by ASNR) - 2 STs
- **Effluent release**

Water-cooled advanced modular reactor

Atmospheric release in Nominal Condition


- Release fractions from 100 Mwe PWR-type SMR applied to the fuel inventory at 20 MWd/kgU (considered representative of a core load at the equilibrium)

Nuclide	Release fraction	Source Term [Bq/y]	Nuclide	Release fraction	Source Term [Bq/y]
Kr-85m	3.30E-04	1.964E+13	Te-132	3.30E-10	8.910E+07
Xe-133	3.30E-04	1.317E+14	Ba-139	8.26E-10	2.974E+08
I-131	3.30E-04	9.176E+08	Ba-140	8.26E-10	2.874E+08
I-132	4.96E-09	1.366E+09	Sr-90	8.27E-10	1.464E+07
I-133	4.95E-09	1.970E+09	Mo-99	8.25E-10	2.978E+08
I-134	4.95E-09	2.237E+09	Ru-106	3.29E-10	2.346E+07
I-135	4.95E-09	1.866E+09	Rh-105	3.31E-10	5.097E+07
Rb-88	4.95E-09	2.046E+05	Y-90	8.27E-10	1.480E+07
Cs-134	8.25E-10	1.450E+07	Y-91	8.25E-10	2.285E+08
Cs-137	8.24E-10	1.774E+07			

P. M. Udiyani et al 2018 J. Phys.: Conf. Ser. **962** 012035



Water-cooled advanced modular reactor Atmospheric release in Severe accident conditions

- 600 postulated MBLOCAs in a generic PWR KONVOI-1300 NPP computed by ASTEC
- **Max, Min, Mean** release rates computed and applied to the fuel inventory at **20, 40, and 60 MWd/kgU**



Water-cooled advanced modular reactor Atmospheric release in Severe accident conditions

- ASTEC analyses for a generic SMR (SBLOCA+SBO) with and w/o FCVS for fuel inventory at 20 and 60 MWd/kgU
- Source term for Cs-134, Cs-137, I-131, I-132, I-133, Kr-85, Xe-133, Xe-133M, Xe-135, and Ru-103



Water-cooled advanced modular reactor

Effluent release

- <https://www.nrc.gov/docs/ML2330/ML23304A359.pdf>
- [https://gda.rolls-royce-smr.com/assets/documents/documents/revised---rr-smr-e3s-case-chapter-29--quantification-of-radioactive-effluent-discharges-and-proposed-limits-gda-website-jm-redactions-check-\(002\)_ssx.pdf](https://gda.rolls-royce-smr.com/assets/documents/documents/revised---rr-smr-e3s-case-chapter-29--quantification-of-radioactive-effluent-discharges-and-proposed-limits-gda-website-jm-redactions-check-(002)_ssx.pdf)




Lead-cooled advanced modular reactor

- ALFRED demonstrator
- Fuel inventories at different burn-up (20, 25, 30, 50, 75 MWd/kgU) computed by SERPENT
- Source terms for severe accident initiated by a flow blockage for a fuel assembly with local hot spots and cladding failure
 - ASTEC + Fission product transport method + release from the fuel rods, NUREG-1465

Lead-cooled advanced modular reactor

Atmospheric release in Severe accident conditions

- Source term for fuel inventory at 20, 25, 30, 50, 75 MWd/kgU
- Source term for Kr-78, Kr-85, Xe-133, Xe-134, Xe-135, Xe-136, Cs-134, Cs-135, Cs-136, Cs-137, Sr-89, Sr-90, I-129, I-130, I-131, I-135, Rb-86, Rb-87, Se-79, Sb-124, Sb-125, Sb-126, Te-123, Te-127, Te-128, Te-129, Te-130, Te-132



Gas-cooled advanced modular reactor

- Derived by a single 250 MWth pebble bed HTGR module with 700°C reactor coolant outlet temperature (INL) - fuel inventory rescaled by power
- Fuel inventory: TRIstructural ISOtropic (TRISO) fuel in cylindrical compacts, stacked in prismatic graphite blocks*
- Source terms for
 - Nominal condition
 - Severe accidents (three scenarios considered)

*Lowry, P. (October 2012). Scoping analysis of source term and functional containment. Idaho National Laboratory, Idaho, USA: INL/EXT-11-24034 Revision 2.

Gas-cooled advanced modular reactor

Atmospheric release in Nominal Condition

- 50% and 95% upper bound values of the attenuation factors
- Uncertainty distribution for each safety barrier taken into account, e.g., heavy metal contamination, SiC coating defects, fuel particle kernel, graphite, and building

Lowry, P. (October 2012). Scoping analysis of source term and functional containment. Idaho National Laboratory, Idaho, USA: INL/EXT-11-24034 Revision 2.

Nuclide	Source term (50%) [Bq]	Source term (95%) [Bq]
Xe-133	4.470E+11	4.470E+12
Kr-85	2.344E+09	2.344E+10
Kr-88	2.282E+11	2.282E+12
I-131	2.466E+11	2.466E+12
I-133	4.440E+11	4.440E+12
Te-132	3.345E+11	3.345E+12
Cs-137	4.168E+09	2.084E+12
Cs-134	4.689E+09	2.344E+12
Sr-90	5.210E+11	6.946E+12
Ag-110m	8.658E+12	8.658E+13
Ag-111	9.102E+14	9.102E+15
Sb-125	2.898E+08	2.898E+11
Ru-103	4.440E+09	1.480E+11
Ce-144	2.874E+09	9.581E+10
La-140	4.026E+09	1.342E+11
Pu-239	5.742E+04	5.742E+06

Gas-cooled advanced modular reactor

Atmospheric release in Severe accident Condition

- Scenario - loss of the He forced cooling
 - loss of heat transport and shutdown cooling
 - sudden He depressurization in the He pressure boundary
 - venting the reactor building

Short-term release [Bq]		Long-term release [Bq]	
50% confidence	95% confidence	50% confidence	95% confidence
2.979E+12	4.673E+14	1.111E+13	1.616E+15

- Short-term release assumed lasting many hours
- Long-term release: the core heat-up is postulated to heat-up for 50 hours, followed by the release of fission products lasting for the next 40 hours

Lowry, P. (October 2012). Scoping analysis of source term and functional containment. Idaho National Laboratory, Idaho, USA: INL/EXT-11-24034 Revision 2.

Gas-cooled advanced modular reactor

Atmospheric release in Severe accident Condition

- Scenario - steam generator tube break followed by water ingress
 - reactor trip
 - loss of heat transport and shutdown cooling
 - water ingress
 - isolation of both the main steam and feedwater lines
 - over-pressurization of the He pressure boundary
 - venting the reactor building

Short-term release [Bq]		Long-term release [Bq]	
50% confidence	95% confidence	50% confidence	95% confidence
2.308E+14	9.279E+14	1.177E+13	9.729E+14

Lowry, P. (October 2012). Scoping analysis of source term and functional containment. Idaho National Laboratory, Idaho, USA: INL/EXT-11-24034 Revision 2.

Gas-cooled advanced modular reactor

Atmospheric release in Severe accident Condition

- Scenario - very conservative (derived by former studies on the High Temperature engineering Test Reactor, HTTR)
- Source term of Xe-133, Kr-85, Kr-88, I-131, I-133, Te-132, Cs-137, Cs-134, Sr-90, Ag-110m, Ag-111, Sb-125, Ru-103, Ce-144, La-140

Nuclides group (elements)	Release fraction (%)
Noble Gases (Xe, Kr)	30
Iodine (I)	15
Cesium and Strontium (Cs, Te, Sr, Ba, Rb)	15
Antimony (Sb)	1.2
Molybdenum (Mo, Ru, Rh, Tc)	2.8
Cerium (Ce)	0.3
Lanthanides (La, Pr, Sm, Eu, Nb, Y, Nd, Zr, Pm)	0.1

Hummel, D., Chouhan, S., Lebel, L., & Morreale, A. (2020). Radiation dose consequences of postulated limiting accidents in small. Annals of Nuclear Energy 137.

Typical SMR Site Characteristics

- Preferably located 100 m from sea/coast or adjacent to suitable surface water (river, reservoir) for cooling access
- Flat terrain with gentle slopes, outside flood zones and seismic faults
- Not located on protected habitat, aquifer recharge zones, wetlands, or contiguous to dense population
- Good access to infrastructure: roads, rail, transmission lines, and low-risk surrounding industrial sites

[GDA Step 2 of the Rolls-Royce SMR: fundamental assessment full report - GOV.UK](#)

[Geographical Considerations in Site Selection for Small Modular Reactors in Saskatchewan](#)

Database of the Sites


- Four sites
 - **Industrial site** next to heavy/chemical industry (Stein, Limburg, Netherlands)
 - **Urbanized site** - close to both urban and industrial zones (Arnhem, Gelderland, Netherlands)
 - **Natura2000 site** - Petten (Netherlands)
 - **Urbanized site** for district heating (Helsinki, Finland)
- Quite detailed and extensive set of information sources (websites, maps, tables) has been collected and implemented in the database

Database of siting: status

- Information collected related to
 - Population
 - Buildings
 - Geology
 - Hydrology
 - Ecology, flora, fauna
 - Maps, e.g., LiDAR datasets of the City of Helsinki
 - Marine traffic
 - Risks



Marine Traffic in the Helsinki ports



Co-funded by
the European Union

Summary and Outlook

- The CATAPULT database of source term and siting has been assessed and going to be employed for the planned dose impact and the environmental transport studies
- The database is fully documented
- The database is a **living** document, namely under continuous extension, e.g.:
 - ^3H and ^{14}C release (UNSCEAR 2024 Report, United Nations, 2025)
 - Exploitation is going on → working teams on environmental science, radiation dosimetry, and nuclear operation and regulatory compliance (cross-fertilization!)
 - Source term in nominal condition in a generic Lead-cooled reactor
 - Effluent release in Gas- and Lead-cooled reactors